








Thermobloc 195 - Performances acoustiques

Coffre posé derrière linteau









Isolement acoustique Dnew+Ctr du coffre Tablier enroulé	52	53	54	55	56	57	58	59
Sans grille		T			P1	P3	P9	
Pose sous plafond								P9
Avec grille hygro 37dB	T			P1				

	Configuration acous- tique Tablier	T	P1	P3	P9
					
Sans grille 	Enroulé	53 57 (-5 ; -4) AC21-03026 Essai 31	56 59 (-1 ; -3) AC21-03026 Essai 34	57 60 (-1 ; -3) AC21-03026 Essai 21	58 62 (-1 ; -4) AC21-03026 Essai 10
	Déroulé	51 54 (0 ; -3) AC21-03026 Essai 33	53 56 (-1 ; -3) AC21-03026 Essai 35	56 60 (-1 ; -4) AC21-03026 Essai 22	57 61 (-1 ; -4) AC21-03026 Essai 18
Pose sous plafond 	Enroulé				59 62 (-1 ; -3) AC21-03026 Essai 46
	Déroulé				57 60 (-1 ; -3) AC21-03026 Essai 47
Avec grille hygro 37dB 	Enroulé	52 55 (-1 ; -3) AC21-03026 Essai 37	55 58 (-1 ; -3) AC21-03026 Essai 41		
	Déroulé	50 52 (0 ; -2) AC21-03026 Essai 36	51 54 (-1 ; -3) AC21-03026 Essai 40		

Thermobloc 195 - Performances acoustiques

Coffre posé sous linteau









Isolement acoustique Dnew+Ctr du coffre Tablier enroulé	44	45	46	47	48	49	50	51	52	53
Sans grille			T		P1		P3	P4		P9
Avec grille hygro 37dB	T		P1	P3						
Avec grille hygro 37dB et rallonge acoustique		T			P4					

	Configuration acoustique	Tablier	T	P1	P3	P4	P9
							
Sans grille 	Enroulé		46 52 (-2 ; -6) PV404/19/277/1G	48 53 (-2 ; -5) AC20-26086141-5	50 55 (-2 ; -5) AC20-26086141-8	51 58 (-3 ; -7) AC20-26086141-9	53 59 (-2 ; -6) AC20-26086141-10
	Déroulé		41 46 (-2 ; -5) PV404/19/277/1G	47 53 (-2 ; -6) AC20-26086141-5	49 55 (-2 ; -6) AC20-26086141-8	49 57 (-3 ; -8) AC20-26086141-9	49 57 (-3 ; -8) AC20-26086141-10
Avec grille hygro 37dB 	Enroulé		44 49 (-1 ; -5) PV404/19/277/1H	46 51 (-1 ; -5) PV404/19/277/1K	47 52 (-1 ; -5) PV404/19/277/1M		
	Déroulé		39 43 (-1 ; -4) PV404/19/277/1H	40 45 (-2 ; -5) PV404/19/277/1K	41 45 (-2 ; -4) PV404/19/277/1M		
Avec grille hygro 37dB et rallonge acoustique 	Enroulé		45 50 (-1 ; -5) PV404/19/277/1I			48 56 (-3 ; -8) PV404/19/277/1N	
	Déroulé		40 44 (-1 ; -4) PV404/19/277/1I			43 50 (-2 ; -7) PV404/19/277/1N	

Thermobloc 225 - Performances acoustiques

Coffre posé derrière linteau



Isolement acoustique Dnew+Ctr du coffre Tablier enroulé	46	47	48	49	50	51	52	53
Sans grille		T	P1		P3			P9
Avec grille hygro 37dB	T			P1				
Avec grille hygro 37dB et rallonge acoustique		T						

	Configuration acous- tique Tablier	T	P1	P3	P4	P9
						
Sans grille 	Enroulé	47 53 (-2 ; -6) PV404/19/277/1P	48 54 (-1 ; -6) PV404/19/277/1S	50 56 (-1 ; -6) PV404/19/277/1U		53 57 (-2 ; -4) AC20-26086141-1
	Déroulé	43 47 (-1 ; -4) PV404/19/277/1P	45 49 (-1 ; -4) PV404/19/277/1S	46 51 (-1 ; -5) PV404/19/277/1U		48 56 (-2 ; -8) AC20-26086141-1
Avec grille hygro 37dB 	Enroulé	46 50 (-1 ; -4) PV404/19/277/1Q	49 54 (-2 ; -5) PV404/19/277/1T			
	Déroulé	41 44 (-2 ; -3) PV404/19/277/1Q	41 44 (-1 ; -3) PV404/19/277/1T			
Avec grille hygro 37dB et rallonge acoustique 	Enroulé	47 52 (-1 ; -5) PV404/19/277/1R				
	Déroulé	42 45 (-1 ; -3) PV404/19/277/1R				

Thermobloc 225 - Performances acoustiques

Coffre posé sous linteau

Isolement acoustique Dnew+Ctr du coffre Tablier enroulé	45	46	47	48	49	50
Sans grille		T	P1	P4		P9
Avec grille hygro 37dB	T	P3	P4			

Configuration acous- tique Tablier		T	P1	P3	P4	P9
Sans grille 	Enroulé	46 50 (-1 ; -4) PV404/19/277/1W	47 52 (-2 ; -5) PV404/19/277/1Y		48 55 (-2 ; -7) PV404/19/277/1AA	50 56 (-2 ; -6) AC20-26086141-2
	Déroulé	41 45 (-1 ; -4) PV404/19/277/1W	45 48 (-1 ; -3) PV404/19/277/1Y		45 52 (-2 ; -7) PV404/19/277/1AA	47 55 (-2 ; -8) AC20-26086141-2
Avec grille hygro 37dB 	Enroulé	45 49 (-1 ; -4) PV404/19/277/1X		46 51 (-2 ; -5) PV404/19/277/1Z	47 54 (-2 ; -7) PV404/19/277/1AB	
	Déroulé	40 43 (-1 ; -3) PV404/19/277/1X		41 45 (-1 ; -4) PV404/19/277/1Z	43 48 (-1 ; -5) PV404/19/277/1AB	